

A silhouette of a construction worker wearing a hard hat and holding a shovel, standing against a dramatic sunset sky with orange and red clouds. The worker is on the left side of the frame, facing right. The background is a gradient of colors from dark blue at the top to bright orange and red at the bottom, with scattered white clouds. In the top right corner, there is a graphic element consisting of a red arrow pointing upwards and to the right, with a blue and green curved line below it.


FROM THE **GROUND UP**

OGA CONFERENCE 2018

February 27 - 28 | The Westin Toronto Airport | Toronto, ON



Geo-Exchange w/ Solar Thermal



Evergreen Brickworks Building 16

A Brookfield Company

- Introduction
- Initial Assessment
- Evergreen Campus and Building 16
- Project Goals
- Project Obstacles
- Modelling and Evaluation
- Systems Overview
- Lessons Learned
- Final Outcome

### **Nuno Duarte, P.Eng.**









BGIS - VP Professional Services

### **Greg Woodhouse, P.Eng.**

BGIS – Director, Engineering



- BGIS provided a campus wide Carbon Neutral assessment and roadmap
- Reviewed all existing buildings accounting for preliminary plans for the Building 16 renovation
- Determined that some combination of a geo-exchange heat pump system and renewables were required to reduce/eliminate the reliance on natural gas
- BGIS Carbon Neutral Assessment was used to obtain grants and incentives to undertake this capital intensive project

	<b>Enhanced Envelope</b> opportunities were identified to reduce energy use by 13% at a cost of \$2,600,000	Eliminates <b>66 tons</b> of carbon emissions
	<b>HVAC</b> opportunities, including a ground source heat pump system, were identified to reduce energy use by 23% at a cost of \$1,120,000	Eliminates <b>116 tons</b> of carbon emissions
	<b>Lighting</b> opportunities were identified to reduce energy use by 5% at a cost of \$125,000	Eliminates <b>3 tons</b> of carbon emissions
	<b>Operational opportunities</b> were identified, including plug load reduction strategies, to reduce energy by 5% at a cost of \$100,000	Eliminates <b>2 tons</b> of carbon emissions
	<b>Biofuel</b> opportunities were identified to reduce energy use by 4% at a cost of \$200,000	Eliminates <b>23 tons</b> of carbon emissions
	<b>Controls Upgrades and Optimization</b> opportunities were identified to reduce energy use by 7% at a cost of \$100,000	Eliminates <b>17 tons</b> of carbon emissions
	<b>Domestic Hot Water</b> opportunities were identified at a cost of \$25,000. No energy savings are realized.	Eliminates <b>18 tons</b> of carbon emissions
	<b>Solar PV and Thermal</b> opportunities were identified to reduce energy use by 28% at a cost of \$1,900,000	Eliminates <b>95 tons</b> of carbon emissions

- Near Carbon Neutral Building
- First step in Near Carbon Neutral Campus
- Promote education in sustainability and renewables via the space
  - Visible system within building
- Extensive use of renewables
- Maximize all available funding avenues






A summary of the building heating and cooling requirements is as follows:

Peak heating load – 1578 kBTU/hr

Peak cooling load – 488 kBTU/hr





Total annual heating demand – 3431 MBTU

Total annual cooling demand – 188 MBTU




- Uninsulated old brick building
- Uninsulated Roof
- Roof structure
- Heritage building
- Building directly in flood plane
- Bore field spatial limitations


- Building modelled using IES
  - Loads calculated
  - CFD Analysis
  - Dry bulb vs. perceived temperature analysis
- Geo-source Analysis – HGS and Solar Tomorrow
  - Preliminary solar thermal investigation
  - Borefield sizing
  - Borefield temp vs. time
  - Solar Thermal array sizing
  - NPC analysis




9.1 Event Space CFD Analysis for R0



9.2 Event Space CFD Analysis for R5



9.3 Event Space CFD Analysis for R20



## Modelling Internal Temperatures:

- The facility would be tempered in the colder months
- Analyzed Dry Bulb and Dry Resultant temperatures of each space within the facility
- Variables:
  - Floor temperature
  - Roof insulation R values


## 6. Zone temperature analysis with radiant floor heating/cooling and different roof insulation scenario

### 6.1 Event Space Temperature profile depending on the month and on the roof insulation.


Event Space	Occupied desired Air Temperature SP (Heating, Cooling)	Room Dry Bulb Temperature (°F)			Room Dry Resultant Temperature (°F)		
		DB Max, Mean, Min, R0	DB Max, Mean, Min, R5	DB Max, Mean, Min, R20	DR Max, Mean, Min, R5	DR Max, Mean, Min, R20	DR Max, Mean, Min, R20
January	66°F(18.9°C), 80.6°F(27°C)	42°F(5.6°C), 36°F(2.2°C), 30°F(-1.1°C)	52°F(11.1°C), 49°F(9.4°C), 46°F(7.8°C)	55°F(12.8°C), 53°F(11.7°C), 51°F(10.6°C)	53°F(11.7°C), 47°F(8.3°C), 41°F(5°C)	62°F(16.7°C), 57°F(13.9°C), 53°F(11.7°C)	65°F(18.3°C), 62°F(16.7°C), 54°F(12.2°C)
February	66°F(18.9°C), 80.6°F(27°C)	52°F(11.1°C), 46°F(7.8°C), 41°F(5°C)	59°F(15°C), 56°F(13.3°C), 54°F(12.2°C)	61°F(16.1°C), 60°F(15.6°C), 58°F(14.4°C)	62°F(16.7°C), 55°F(12.8°C), 50°F(10°C)	68°F(20°C), 63°F(17.2°C), 60°F(15.6°C)	70°F(21.1°C), 67°F(19.4°C), 64°F(17.8°C)
March	66°F(18.9°C), 80.6°F(27°C)	57°F(13.9°C), 53°F(11.7°C), 49°F(9.4°C)	60°F(15.6°C), 59°F(15°C), 58°F(14.4°C)	63°F(17.2°C), 62°F(16.7°C), 61°F(16.1°C)	63°F(17.2°C), 60°F(15.6°C), 57°F(13.9°C)	67°F(19.4°C), 66°F(18.9°C), 64°F(17.8°C)	69°F(20.6°C), 67°F(19.4°C), 66°F(18.9°C)
April	66°F(18.9°C), 80.6°F(27°C)	68°F(20°C), 62°F(16.7°C), 58°F(14.4°C)	70°F(21.1°C), 69°F(20.6°C), 67°F(19.4°C)	70°F(21.1°C), 69°F(20.6°C), 68°F(20°C)	73°F(22.8°C), 68°F(20°C), 65°F(18.3°C)	75°F(23.9°C), 73°F(22.8°C), 71°F(21.7°C)	75°F(23.9°C), 73°F(22.8°C), 71°F(21.7°C)
May	66°F(18.9°C), 80.6°F(27°C)	74°F(23.3°C), 71°F(21.7°C), 68°F(20°C)	74°F(23.3°C), 73°F(22.8°C), 68°F(20°C)	74°F(23.3°C), 73°F(22.8°C), 68°F(20°C)	74°F(23.3°C), 72°F(22.8°C), 71°F(21.7°C)	78°F(25.6°C), 75°F(23.9°C), 73°F(22.8°C)	78°F(25.6°C), 75°F(23.9°C), 73°F(22.8°C)
June	66°F(18.9°C), 80.6°F(27°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)
July	66°F(18.9°C), 80.6°F(27°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	81°F(27.2°C), 78°F(25.6°C), 75°F(23.9°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)	82°F(27.8°C), 79°F(26.1°C), 76°F(24.4°C)
August	66°F(18.9°C), 80.6°F(27°C)	83°F(28.3°C), 80°F(26.7°C), 74°F(23.3°C)	83°F(28.3°C), 80°F(26.7°C), 74°F(23.3°C)	83°F(28.3°C), 80°F(26.7°C), 74°F(23.3°C)	83°F(28.3°C), 80°F(26.7°C), 76°F(24.4°C)	83°F(28.3°C), 80°F(26.7°C), 76°F(24.4°C)	83°F(28.3°C), 80°F(26.7°C), 76°F(24.4°C)
September	66°F(18.9°C), 80.6°F(27°C)	74°F(23.3°C), 69°F(20.6°C), 63°F(17.2°C)	74°F(23.3°C), 72°F(22.8°C), 69°F(20.6°C)	74°F(23.3°C), 73°F(22.8°C), 70°F(21.1°C)	78°F(25.6°C), 72°F(22.8°C), 69°F(20.6°C)	78°F(25.6°C), 75°F(23.9°C), 71°F(21.7°C)	78°F(25.6°C), 75°F(23.9°C), 71°F(21.7°C)
October	66°F(18.9°C), 80.6°F(27°C)	65°F(18.3°C), 64°F(17.8°C), 62°F(16.7°C)	68°F(20°C), 67°F(19.4°C), 66°F(18.9°C)	68°F(20°C), 67°F(19.4°C), 66°F(18.9°C)	70°F(21.1°C), 68°F(20°C), 67°F(19.4°C)	73°F(22.8°C), 71°F(21.7°C), 70°F(21.1°C)	73°F(22.8°C), 71°F(21.7°C), 70°F(21.1°C)
November	66°F(18.9°C), 80.6°F(27°C)	56°F(13.3°C), 52°F(11.1°C), 49°F(9.4°C)	62°F(16.7°C), 61°F(16.1°C), 60°F(15.6°C)	65°F(18.3°C), 63°F(17.2°C), 63°F(17.2°C)	68°F(20°C), 59°F(15°C), 56°F(13.3°C)	68°F(20°C), 67°F(19.4°C), 65°F(18.3°C)	70°F(21.1°C), 69°F(20.6°C), 68°F(20°C)
December	66°F(18.9°C), 80.6°F(27°C)	45°F(7.2°C), 44°F(6.7°C), 43°F(6.1°C)	51°F(10.6°C), 51°F(10.6°C), 51°F(10.6°C)	53°F(11.7°C), 51°F(10.6°C), 51°F(10.6°C)	53°F(11.7°C), 52°F(11.1°C), 51°F(10.6°C)	58°F(14.4°C), 58°F(14.4°C), 57°F(13.9°C)	60°F(15.6°C), 60°F(15.6°C), 60°F(15.6°C)
Worst day of the year in heating	66°F(18.9°C), 80.6°F(27°C)	34°F(1.1°C), 33°F(0.6°C), 32°F(0°C)	42°F(5.6°C), 41°F(5°C), 41°F(5°C)	46°F(7.8°C), 45°F(7.2°C), 45°F(7.2°C)	47°F(8.3°C), 46°F(7.8°C), 45°F(7.2°C)	53°F(11.7°C), 53°F(11.7°C), 53°F(11.7°C)	56°F(13.3°C), 55°F(13.3°C), 56°F(13.3°C)
Worst day of the year in cooling	66°F(18.9°C), 80.6°F(27°C)	87°F(30.6°C), 83°F(28.3°C), 77°F(25°C)	87°F(30.6°C), 83°F(28.3°C), 77°F(25°C)	87°F(30.6°C), 83°F(28.3°C), 77°F(25°C)	86°F(30°C), 83°F(28.3°C), 78°F(25.6°C)	86°F(30°C), 83°F(28.3°C), 78°F(25.6°C)	86°F(30°C), 83°F(28.3°C), 78°F(25.6°C)

Definition of Dry resultant: The Dry Resultant is the temperature in °F felt by the occupant if we take into consideration both the air dry bulb temperature and the radiant surfaces heating or cooling effect.

**Solar Thermal Modelling:** Can we do this without a borefield?.....No, we NEED storage.



**Solar thermal energy to the system [Qsol] kWh**



Number of 2.65 m <sup>2</sup> thermal collectors	300
Collector gross area	792 m <sup>2</sup>
Total annual field yield to the system	448,300 kWh
Weight of collector	49 kg
Total weight	14,700 kg
Price (300 collectors, roof mounting hardware, inter-collector fittings)	\$229,000
Estimated number of 70 m (~225 ft) deep boreholes	52
Value of natural gas saved annually (@ \$0.25/m <sup>3</sup> )	\$13,300
CO <sub>2</sub> annual savings	91 ton

### 1.1. Description of tasks

HGS has performed the following tasks:

- Analysis of the building energy simulation results provided by Brookfield engineers
- Calculations confirming ground thermal imbalance, and the need for auxiliary heating
- Finite-element simulation to determine the thermal response of the ground
- Development of a system optimization algorithm to compute COP and financial projections
- Computation of solar energy flow into the ground for varying number of solar thermal panels
- Determination of system COP and financial projections for varying number of solar panels

**Solar Thermal Modelling:** Can we do this without Solar Thermal?.....NO! We NEED heat.

Table 1. Summary of projected costs and system failure time for varying number of solar panels


# of Panels	20-year NPC	40-year NPC	Projected System Failure Time
0	\$2,111,000	\$6,889,000	In year 1
50	\$1,976,000	\$6,052,000	In year 2
100	\$1,879,000	\$5,291,000	In year 4
150	\$1,805,000	\$4,641,000	In year 7
200	\$1,745,000	\$4,113,000	In year 32
225	\$1,719,000	\$3,882,000	N/A
250	\$1,699,000	\$3,682,000	N/A
275	\$1,680,000	\$3,509,000	N/A
300	\$1,666,000	\$3,362,000	N/A




- NPC Analysis

Table 3. Comparative analysis for costs associated with varying numbers of solar panels


1. # of panels	2. Panel Cost Installed	3. Avg. Heating COP	4. Avg. Annual Elec. Cost (\$ .12)	5. Avg. Annual Elec. Cost (\$ .17)	6. 20-year NPC (\$ .12)	7. 20-year NPC (\$ .17)	8. 40-year NPC (\$ .12)	9. System Failure Time
0	\$0.00	2.69	\$105,569	\$149,556	\$2,111,000	\$2,991,000	\$6,889,000	year 1
50	\$120,450	2.94	\$92,753	\$131,400	\$1,976,000	\$2,748,000	\$6,052,000	year 2
100	\$240,900	3.16	\$81,907	\$116,035	\$1,879,000	\$2,562,000	\$5,291,000	year 4
150	\$341,962	3.36	\$73,148	\$103,626	\$1,805,000	\$2,414,000	\$4,641,000	year 7
200	\$430,100	3.54	\$65,746	\$93,140	\$1,745,000	\$2,293,000	\$4,113,000	year 32
225	\$469,322	3.62	\$62,473	\$88,503	\$1,719,000	\$2,239,000	\$3,882,000	N/A
250	\$505,313	3.69	\$59,693	\$84,565	\$1,699,000	\$2,197,000	\$3,682,000	N/A
275	\$538,072	3.75	\$57,092	\$80,880	\$1,680,000	\$2,156,000	\$3,509,000	N/A
300	\$567,600	3.81	\$54,906	\$77,783	\$1,666,000	\$2,123,000	\$3,362,000	N/A




- Bore Field Temperature vs. Time



- Low temperature radiant floor heating and cooling
- Fan-assist natural ventilation
- Two 60 ton heat pumps
- 40 hole borefield
- 260 panel solar thermal array, 8000 sqft
- 100% OA ventilation unit w/ enthalpy wheel
- Natural gas boiler back up



East Parking Lot - Owned by CNR



Under building - New floor already poured

Parking lot – Hard cap, contaminated soil

**SOLAR THERMAL COLLECTORS**

**ST EMERGENCY DRAIN DOWN**

**HEAT PUMPS**

**BOREHOLE FIELD**


**DECOUPLED FIELD/ARRAY**

**ST BUFFER TANK**

**WINTER COOLING**

**WINTER ST HEATING**

**RADIANT FLOOR SYSTEM**



- GENERAL NOTES**
1. FOR SEQUENCING OF INDIVIDUAL PARTS OF SYSTEMS REFER TO MECHANICAL SPECIFICATIONS.
  2. ALL TEMPERATURE SENSORS SHALL BE CONNECTED TO THE BMS.
  3. REFER TO ELECTRICAL FOR WIREWAY, WIRING, CONTROL CONNECTIONS, WIRE MESS UP, EXPANSION TANK AND GAS-VENT/RELIEF INSTALLATION, AND GALVANIC MAKE UP SYSTEMS.
  4. ALL AIR AND RP CONTROL VALVES SHALL BE CLOSED WHEN SYSTEM IS IN COOLING. TO BE COORDINATED IN BMS SEQUENCING.
  5. WINTER COOLING FOR BMS SHALL BE COOLANT DIVERSION FOR ADDITIONAL COOLING PROVIDE COOLANT DIVERSION TO ALL EQUIPMENT WITH NO Bypass SHOWN ON SCHEMATIC OR LAYOUT.
  6. SOLAR THERMAL LOOP AND GROUND LOOP TO USE 20% PROPYLENE GLYCOL.
  7. CONTRACTOR SHALL GOVERNANCE ALL MECHANICAL, SEQUENCE AND MECHANICAL, BMS.
  8. REFER TO BMS FOR WIREWAY AND CONTROL, SEQUENCE AND MECHANICAL SPECIFICATIONS FOR OPERATION AT VALVES.

- CONSTRUCTION NOTES**
1. RADIANT FLOOR MIXING VALVE: TEMPERATURE SHALL NOT BE LESS THAN 60°F IN WINTER. IN WINTER SHUT NORMALLY CLOSED. REFER TO SEQUENCE OF OPERATION.
  2. BYPASS CONTROLLED BY HEAT PUMP CONTROLLER.
  3. CONTROL VALVES FOR SOLAR ARRAY BYPASS AND SOLAR THERMAL STORAGE TANK IS IN USE.
  4. SOLAR THERMAL STORAGE DIVERSION VALVE.
  5. SOLAR THERMAL DIVERSION VALVE.
  6. SOLAR ARRAY BYPASS IS INDICATIVE. REFER TO PLANS FOR EXACT PIPING LAYOUT AND NUMBER OF CONNECTION POINTS. TOTAL 33 CONNECTIONS FROM PANELS ON ROOF.
  7. CONTROL VALVES SHALL BE INTERLOCKED TO BE OPEN OR CLOSED. ST-01 VALVE SHALL OPEN IF HEAT VALUE REMAINS CLOSED AND ST-01 REACHES MAX TEMP. ALARM @ 50°F.
  8. CONTROL VALVE TO PUMP SHALL BE CLOSED IN HEATING AND PUMPS SHALL BE BYPASSED.
  9. CONTROL VALVE SHALL BE ACTUATED TO SELECT HEAT FROM BOREHOLE FIELD WHEN WINTER TEMPERATURE SET POINTS CAN NOT BE MET DURING EXTREME WEATHER. VALVE SHALL ALSO BE FULLY OPENED FOR TEMPORARY HEAT PRIOR TO CONSTRUCTION OF SOLAR THERMAL SYSTEM.
  10. AUTOMATIC EMERGENCY DRAIN VALVE TO BE OPENED AT 200°F.
  11. WINTER HEAT INJECTION DIRECT FROM SOLAR.
  12. WINTER COOLING SUPPLY TO FAN COILS.
  13. ST-01 IS A BMS BUFFER TANK.
  14. PUMP & PIPING TO BE INSTALLED IN FUTURE PHASE. PIPING SHOWN IN LIGHT IS NOT INCLUDED IN THIS PHASE.

**Proposed** →

**Avoided** →

Option	Yearly Electricity (kWh)	Yearly Natural Gas m3 (ekWh)	Yearly Total Energy usage (ekWh)	Yearly Total Energy Cost (\$)	Yearly Carbon Generated (eCO2tons)
A	1,010,000 kWh	0 m3 (0 ekWh)	1 010 000 ekWh	\$121 000	41 eCO2tons
B	200 000 kWh	380 000 m3 ( 4 000 000 ekWh)	4 200 000 ekWh	\$184 000	688 eCO2tons
C	338 000 kWh	59 500 m3 (625 000 ekWh)	963 000 ekWh	\$114 000	120 eCO2tons

Our modelling shows that Option A, the proposed building design using our solar thermal ground source solution has the lowest carbon output.

- **Projected Annual Carbon Emittance Avoided = 647 tons**
- **Projected Annual Cost Avoidance = \$63,000**

- Know what you don't know...Bring in reinforcements!
- You can't turn off Solar Thermal
- Large scale Solar Thermal is uncharted territory...Plan accordingly
- Work with a build team you can trust:
  - Geosource Energy
  - Ellis Don
  - Engie Multitech